

**Office of the Vice President  
and Chief Financial Officer**  
Finance and Accounting Division  
*Purchasing and Disbursement Services*  
<http://purchasing.ufl.edu/>

102 Elmore Hall  
PO Box 115250  
Gainesville, FL 32611-5250  
352-392-1331  
352-392-8837 Fax

September 28, 2009

**ADDENDUM NUMBER 2 ON INVITATION TO BID ITB10MB-112**

**TITLE: Elevator Modification Cancer Genetics Research Complex.**

The mandatory pre-bid meeting was held September 17, 2009 at 2:00 PM. The bid opening is scheduled for October 6, 2009 at 10:00 AM in Elmore Hall, Radio Road, Gainesville, Florida.

This addendum shall be considered part of the Contract Documents for the above mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract documents, this addendum shall govern and take precedence. Bidders are hereby notified that they shall acknowledge receipt of the addendum.

**NOTES:**

- **The bid opening has been rescheduled for October 6, 2009 at 10:00 AM.**

- Request for Information and Questions and Answers:

Q1: *Review a copy of elevator specifications that Jim Thompson stated he has available on the elevator survey.*


A1: The elevator specifications are generic and do not reflect installed on site, however we can provide you with approved submittals if requested. Note: Approved submittals are not as-built.

Q2: *Clarify that the existing motors will be compatible with new controls. Addendum 1 clarifies the addition of the elevator freight door. Please provide the door specifications for the correct replacement door.*

A2: The contractor is responsible to field check, measure and verify for all components of the elevators (there will not be a change order for mistakes) as well as the fact that for all projects NON-proprietary controls are to be installed. If there are special tools or instruments for maintenance of any part of the elevator equipment, it shall be provided as part of this project to owner. We do urge the contractor to contact Jim Thompson for examination of the system.

Q3: *Clarify Technical Specifications, page 15, call for NON-Proprietary controls to be installed. Addendum 1, item 1.2 states that a diagnostic test, device or service tool be provided. Does this mean that proprietary controls are allowed to be installed?*

A3: Proprietary controls are NOT allowed. We are looking for NON-Proprietary controls.



Mercedes Bongiovanni

Purchasing Coordinator II

**PLEASE ACKNOWLEDGE RECEIPT OF ADDENDUM AND RETURN WITH YOUR BID. FAILURE TO ACKNOWLEDGE YOUR ADDENDUM COULD CONSTITUTE REJECTION OF YOUR BID.**

---

VENDOR NAME

---

VENDOR ADDRESS

---

---

SIGNATURE