



Office of the Vice President
and Chief Financial Officer
Finance and Accounting Division
Purchasing and Disbursement Services
<http://purchasing.ufl.edu/>

102 Elmore Hall
PO Box 115250
Gainesville, FL 32611-5250
352-392-1331
352-392-8837 Fax

July 22, 2009

ADDENDUM NUMBER 6 ON INVITATION TO BID ITB10SVF-102

TITLE: Materials Engineering Bldg. 719 Roof Replacement

The mandatory pre-bid meeting was held July 14, 2009 at 1:30 PM. The bid opening is scheduled for July 29, 2009 at 2:00 PM in Elmore Hall, Radio Road, Gainesville, Florida.

This addendum shall be considered part of the Contract Documents for the above mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract documents, this addendum shall govern and take precedence. Bidders are hereby notified that they shall acknowledge receipt of the addendum.

NOTES:

- Please see attached Ponikvar & Associates Field Order No. 3.

Mercedes Bongiovanni
Purchasing Coordinator II

PLEASE ACKNOWLEDGE RECEIPT OF ADDENDUM AND RETURN WITH YOUR BID. FAILURE TO ACKNOWLEDGE YOUR ADDENDUM COULD CONSTITUTE REJECTION OF YOUR BID.

VENDOR NAME

VENDOR ADDRESS

SIGNATURE



P R I N C I P A L S

Jack Ponikvar, RA
Joseph Walker, RA
Apyrl Williamson, RA

S E N I O R A S S O C I A T E

Michael Buchanan

DATE: 22 July 2009

FIELD ORDER NO: THREE (3)

TO: Chandler Rozear, Project Manager
UF PPD – Architecture/Engineering Dept.
Building 700, Radio Road
Gainesville, FL 32611-7715

PROJECT: UF Materials Engineering
Building 719 Roof Replacement

OWNER: University of Florida
Gainesville, Florida

ARCHITECT'S PROJECT NO: 08016
OWNER'S PROJECT NO: 1031611

You are hereby directed to execute promptly this Field Order which interprets the Contract Documents or orders minor changes in the Work without change in Contract Sum or Contract Time.

If you consider that a change in Contract Sum or Contract Time is required, please submit your itemized proposal to the Architect immediately and before proceeding with this Work. If your proposal is found to be satisfactory and in proper order, this Field Order will in that event be superseded by a Change Order.

DESCRIPTION: Roof Insulation Clarification

F3-1. CLARIFICATION: (RFI 1)

Question: The drawings for the roof insulation on the wood structure part of this project show a rigid insulation with 1/2" dens deck on top. According to some of the roofers, there is no spec for this part of the roof. May I suggest that you consider putting lwc on this roof? That is what we did on the last Engineering Buildings. It would be more economical to use the lwc since I am on the job already doing the main roof. Weight would not be a factor as we would pour a 1" thickness of nvs. at the roof perimeter and have minimal slope to the center of the roof to allow for drainage.

Response: *The LWIC installation is acceptable as a substitute for the rigid insulation shown on the plans.*

PONIKVAR & ASSOCIATES, INC.

Joe Walker, RA
Project Manager

cc: file

A R C H I T E C T S
AA0002486

5700 SW 34th Street Suite 5700
Gainesville, Florida 32608
Phone
(352) 372-1378
Fax
(352) 378-1281
Email
design@ponikvar.com