

Office of the Vice President
and Chief Financial Officer
Finance and Accounting Division
Purchasing and Disbursement Services
<http://purchasing.ufl.edu/>

102 Elmore Hall
PO Box 115250
Gainesville, FL 32611-5250
352-392-1331
352-392-8837 Fax

July 27, 2009

ADDENDUM NUMBER 8 ON INVITATION TO BID ITB10SVF-102

TITLE: Materials Engineering Bldg. 719 Roof Replacement

The mandatory pre-bid meeting was held July 14, 2009 at 1:30 PM. The bid opening is scheduled for July 29, 2009 at 2:00 PM in Elmore Hall, Radio Road, Gainesville, Florida.

This addendum shall be considered part of the Contract Documents for the above mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract documents, this addendum shall govern and take precedence. Bidders are hereby notified that they shall acknowledge receipt of the addendum.

NOTES:

- Q: "On the long penthouse roof, there are currently ridge vents. They are not on the plans and there is not a detail for them. Are they to remain or to be removed and roofed over?"



- A: The existing doghouse roof vents are to be removed, patched and prepared for new roof system installation.

Mercedes A. Bongiovanni

Mercedes Bongiovanni
Purchasing Coordinator II

PLEASE ACKNOWLEDGE RECEIPT OF ADDENDUM AND RETURN WITH YOUR BID. FAILURE TO ACKNOWLEDGE YOUR ADDENDUM COULD CONSTITUTE REJECTION OF YOUR BID.

VENDOR NAME

VENDOR ADDRESS

SIGNATURE