

Office of the Vice President
and Chief Financial Officer
Finance and Accounting Division
Purchasing and Disbursement Services
<http://purchasing.ufl.edu/>

102 Elmore Hall
PO Box 115250
Gainesville, FL 32611-5250
352-392-1331
352-392-8837 Fax

August 19, 2009

ADDENDUM NUMBER 2 ON INVITATION TO BID ITB10SVF-104YC

TITLE: Quick Response Electrical Contractor Annual Contract


The mandatory pre-bid meeting will be held September 1, 2009 at 2:00 PM in the Physical Plant Division, A/E Main Street Trailer, Building 270, Radio Road, Gainesville, Florida.

This addendum shall be considered part of the Contract Documents for the above mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract documents, this addendum shall govern and take precedence. Bidders are hereby notified that they shall acknowledge receipt of the addendum.

NOTES:

Please see below question and answer:

- Q1. There are 3 panelboards listed under the unit price section and the descriptions are very vague. I have listed them below.
1. 16151 200amp, 120/208 Volt panelboard-main lugs only, 3 phase - Is this indoor or outdoor?
 2. 16152 200amp, 120/208 Volt panelboard-disconnect, 3 phase - Is this indoor or outdoor? Is this a main breaker panel or disconnect?
 3. 16153 200amp, 277/480 Volt panelboard-disconnect, 3 phase - Is this indoor or outdoor? Is this a main breaker panel or disconnect?
- A1. These items should all be indoor units with further clarifications as follows:
1. 16151 200amp, 120/208 Volt **Interior** panelboard, **42 pole**, Main Lugs Only, 3 Phase.
 2. 16152 200amp, 120/208 Volt **Interior Disconnect Switch**, 3 Pole, 3 Phase.
 3. 16153 200amp, 277/480 Volt **Interior Disconnect Switch**, 3 Pole, 3 Phase.



Mercedes Bongiovanni
Purchasing Coordinator II

PLEASE ACKNOWLEDGE RECEIPT OF ADDENDUM AND RETURN WITH YOUR BID. FAILURE TO ACKNOWLEDGE YOUR ADDENDUM COULD CONSTITUTE REJECTION OF YOUR BID.

VENDOR NAME

VENDOR ADDRESS

SIGNATURE