

Office of the Vice President
and Chief Financial Officer
Finance and Accounting Division
Purchasing and Disbursement Services
<http://purchasing.ufl.edu/>

102 Elmore Hall
PO Box 115250
Gainesville, FL 32611-5250
352-392-1331
352-392-8837 Fax

September 16, 2009

ADDENDUM NUMBER 3 ON INVITATION TO BID ITB10SVF-105YC


TITLE: Quick Response Plumbing Contractor Annual Contract

The mandatory pre-bid meeting was held September 10, 2009 at 10:00 AM in the Physical Plant Division, A/E Main Street Trailer, Building 270, Radio Road, Gainesville, Florida. The bid opening is scheduled for September 23, 2009 at 2:00 PM in Elmore Hall, Room 101, Radio Road, Gainesville, Florida.

This addendum shall be considered part of the Contract Documents for the above mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original Contract documents, this addendum shall govern and take precedence. Bidders are hereby notified that they shall acknowledge receipt of the addendum.

NOTES:

- Q1: *Item 15100 (piping) – Do we include insulation? Is piping accessible, is it in the wall, or in plenum? Price per foot is dependent upon location, how should we formulate our price?*
A1: Assume piping to be in plenum – not insulated.
- Q2: *Item 06652 states “American standard Aqualyn 13x19” Aqualyn sink is actually 20x17. It also states it is self-rimming and undermount? How can it be self-rimming and undermount at the same time? We suggest Kohler 20x17 self-rimming. Do we supply a composite vanity countertop?*
A2: Kohler 20x17 self-rimming is fine – countertop to be supplied by plumbing contractor for this contract.
- Q3: *Item 02111 – Is there a dump site on campus?*
A3: No - debris is to be transported to an approved landfill.
- Q4: *Item 15408 – Elkay no longer offers 19x21 sinks. We suggest 19x19.*
A4: The 19x19 is acceptable.
- Q5: *Items 15412 and 15413 – It asks for a price on a new urinal and we with chair. Is this to replace the existing? Do you want us to include a price to remove the old fixture and chair and replace with new?*
Q5 Assume removal of the old fixture and chair and replace with new.



Mercedes Bongiovanni
Purchasing Coordinator II

PLEASE ACKNOWLEDGE RECEIPT OF ADDENDUM AND RETURN WITH YOUR BID. FAILURE TO ACKNOWLEDGE YOUR ADDENDUM COULD CONSTITUTE REJECTION OF YOUR BID.

VENDOR NAME

VENDOR ADDRESS

SIGNATURE